
AA View



Spring box levels				
Code	Designation	Fonctional Level	Absolute Level	Level From Peg
A	Lowest spring eye level			
B	Highest spring eye level			
C	Highest natural ground level around spring box (before spring digging)			
0	Box inlet level	Lowest eye A - D x 2%	≤ A - D x 2%	
1	Ground level below slab	Washout 2 -10 cm	0 - 22 cm	
2	Washout Level	Inlet 0 -12 cm	0 - 12 cm	
3	Overflow Level	Washout 2 + 10 cm	0 - 2 cm	
4	Outlet Level	Washout 2 + 5 cm	0 - 7 cm	
5	Air-vent Level	Washout 2 + 15 cm	0 + 3 cm	
6	Top cutting foundation level toward box	Washout 2 + 32 cm	0 + 20 cm	
7	Top cutting foundation level toward eyes	Highest eye B + 20 cm		
8	Box Height	Ground C + 40 cm		
9	Cutting foundation depth (or down to stone level)	A - 40 cm (more if loose soil)		
10	Cutting foundation depth (toward box)	1 - 28 cm	0 - 50 cm	
MF4-F21-V2.1 Spring with mold - Levels		Update: 2026	Unit: cm	PROCEED